

TECHNICAL DATA

Fluke i1010 AC/DC Current Clamp



Key features

- The Fluke i1010 AC/DC current clamp is a battery-powered Hall-effect probe that extend the current ranges of Fluke tools, measuring DC current from 1 A to 1000 A and AC current from 1 A to 600A.
- Provides accurate current reading without breaking the circuit.
- Compatible with most Fluke multimeters.
- CAT III 600 V safety rating

Product overview: Fluke i1010 AC/DC Current Clamp

Fluke current clamps extend the current ranges of Fluke tools. The Fluke i1010 AC/DC current clamp is highly reliable, measures 1 A to 1000 A and provides accurate current reading without breaking the circuit. This clamp measures both ac and dc current with a large jaw, battery-powered Hall-effect probe that gives access to difficult to reach areas. Compatible with most Fluke multimeters.

Specifications: Fluke i1010 AC/DC Current Clamp

| Specifications | |
|-----------------------|-------------------------|
| Measurement type | Hall sensor |
| Nominal current range | 600 A, AC 1000 A, DC |



| Continuous current range | 1 A - 600 A, AC 1 A - 1000 A, DC |
|---------------------------------------|---------------------------------------|
| Maximum non-desctructive current | 1000 A |
| Lowest measureable current | 0.5 A |
| Basic accuracy | 2% + 0.5 A (% reading + floorspec) |
| Useable frequency | DC - 10 kHz |
| Output level(s) | 1 mV/A |
| Zero error adjustment | Yes |
| Safety Specifications | |
| Safety | CAT III, 600 V |
| Maximum voltage | 600 V |
| Mechanical and General Specifications | |
| Warranty | 1 year |
| Battery life | 9 V, 60 h |
| Maximum conductor diameter | 30 mm 2 x 25 mm |
| Output cable length | 1.6 m |
| Shrouded banana plugs | Yes |



Ordering information



Fluke i1010

Fluke i1010 AC/DC Current Clamp



Fluke. Keeping your world up and running.®

Fluke Corporation PO Box 9090, Everett, WA 98206 U.S.A.

For more information call:

In the U.S.A. (800) 443-5853 In Canada (800) 36-FLUKE From other countries +1 (425) 446-5500 www.fluke.com ©2023 Fluke Corporation. Specifications subject to change without notice. 09/2023

Modification of this document is not permitted without written permission from Fluke Corporation.